

CHONGQING BORIDA CONSTRUCTION MATERIALS CO.,LTD

Block E2, baisha industrial park, jiangjin district, chongqing China

Tel: 15823063319

Email:cz@cqbrd.com

Certificate of Analysis

Product: Naphthalene superplasticizer

Trademark:



Quantity: 20Ton

Production Code: 20051604

Model: BRS

Testing Standard: GB8076-2008
《Concrete Admixture》

Package: 25kg/Bag

Date: 2020.8.02

Production Date: July 3, 2020

Report Date: August 2, 2020

NO	Experimental project	Standard	Result	R/W	
1	Content of Sodium Sulfate %	≤ 18	OK	R	
	PH Value	7-9	8	R	
2	Water reducer rate/%	≥ 14	18.3	R	
3	Air content/%	≤ 3.0	2.6	R	
2	Difference In Setting Time/min	Initial Setting/min	+30	R	
		Finally Setting/min	+45	R	
3	Compressive Strength	1d	≥ 140	152	R
		3d	≥ 130	145	R
4	MPa/%	7d	≥ 125	136	R
		28d	≥ 120	129	R
5	28d Ratio Of Shrinkage	≤ 135	≤ 102	R	
Conclusion: After inspection, BRS meets the standard index value of GB8076-2008 《Concrete Admixture》.					

1: Standard: GB8076-2008 《Concrete Admixture》.

2: Test basis: GB8076-2008 《Concrete Admixture》.

3: Test conclusion: The inspection index of this batch of BRS superplasticizers are in compliance with the GB8076-2008 《Concrete Admixture》 superplasticizer standard technical requirements.

Remarks: When testing the limiting expansion rate and setting time, the detection content of BD-UEA high performance concrete expansion agent is 10%; when testing the compressive strength, the detection content of BD-UEA high performance concrete expansion agent is 5%.

Review:



产品合格证

产品名称: 高效减水剂

产品型号: BRS (标准型)

推荐掺量: 0.5-1.2%

生产批号: 20051604

生产日期: 2020年5月16日

出厂日期: 2020年6月15日

依据标准: GB8076-2008《混凝土外加剂》

本产品经检测合格, 准予出厂!

检测单位 (章):

检验员: _____

杨前广



重庆博锐达建材有限公司

电话: 023-47890168

网址: www.cqbrd.com

